## **Uponor**

## EP heating manifold elbows

Project Information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

l echnical data	
Temp/pressure ratings	140 °F (60 °C) at 87 psi (6 bar)
	158 °F (70 °C) at 72 psi (5 bar)
	176 °F (80 °C) at 58 psi (4 bar)
	194 °F (90 °C) at 44 psi (3 bar)
Prop 65 label required?	Yes

## Product information and application use

Tec

The Engineered Polymer (EP) Heating Manifold Elbow (A2670090) enables connections to supply and return piping from above or below. Two elbows feature different lengths to accommodate tube spacing for the supply and return lines on a EP Heating Manifold for use in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.



Part name	Part no.	Weight per UOM [lbs/UOM]
EP Heating Manifold Elbow, set of 2	A2670090	0.34
Installation	Related applications	
Hand-tighten the elbow to the supply and return on the manifold. For additional information, refer to the instruction sheet. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.	Radiant Heating and Cooling Systems Permafrost Protection Systems Turf Conditioning Systems	

Codes	Standards	Listings	
-	-	-	
Footnotes		Contact information	
		Uponor Inc.	Uponor Ltd.
		5925 148th Street West	6510 Kennedy Road
-		Apple Valley, MN 55124	Mississauga, ON L5T 2X4
		T 800.321.4739	T 888.594.7726
		F 952 891 2008	E 800 638 9517