

Repair couplings

| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

 Material
 Brass

 End type 1
 Compression 5/16"

 End type 2
 Compression 5/16"

Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar)

180 °F (82 °C) at 100 psi (6.9 bar 200 °F (93 °C) at 80 psi (5.5 bar)

Prop 65 label required? Yes

Product information and application use

Use 5 /16" Repair Coupling to connect 5 /16" Wirsbo hePEX™ tubing. This one-piece repair coupling comes as an assembly. No other fittings are necessary.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | Weight per UOM [lbs/UOM] |
|-----------------------|----------|----------|----------|----------|-----------------------------|
| 5/16" Repair Coupling | A4010313 | 1.736 | 0.86 | 0.86 | 0.15 |

| Installation | Related applications |
|---|-------------------------------------|
| Slide the nut and compression insert onto the tubing. Place the fitting inside the tubing and thread the nut onto the fitting. For more information, refer to the Uponor Radiant Floor Heating Installation Handbook. | Radiant Heating and Cooling Systems |
| | Permafrost Protection Systems |
| | Turf Conditioning Systems |

| Codes | Standards | Listings |
|-------|-----------|------------|
| - | ASTM F877 | cNSFus-rfh |

| Footnotes | Contact is | Contact information | | |
|-----------|------------------------|-------------------------|--|--|
| | Uponor Inc. | Uponor Ltd. | | |
| | 5925 148th Street West | 6510 Kennedy Road | | |
| - | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | | |
| | T 800.321.4739 | T 888.594.7726 | | |
| | F 952.891.2008 | F 800.638.9517 | | |