



**SAMPLE SPECIFICATION  
TYPE B GAS VENT  
MODEL M**

Furnish double-wall, factory-built, chimney listed to UL-441, which conforms to the requirements of NFPA-54 for venting Category I appliances.

Inner wall shall be constructed of aluminum alloy. Outer wall shall be galvanized steel (*Galvalume for Canada*). Chimney shall incorporate an insulating air space between the inner and outer wall. Air space shall be 1/4" from 3" to 6" and 1/2" from 7" to 30" diameters.

Edges of inner and outer walls shall be hemmed to prevent pipe from having exposed sharp edges. Walls shall be interconnected to maintain spacing and prevent separation of the inner and outer walls.

Fittings, flashing, storm collar, cap and appliance connector shall be products of a single manufacturer to assure compatibility. When barometric damper is to be utilized with the chimney, the chimney manufacturer shall provide the necessary fittings to enable its installation.

Vent shall be installed in accordance with the manufacturer's instructions and UL listing. Termination height shall be in accordance with National Fuel Gas Code or local code requirements.

Vent shall be Model M as manufactured by Metal-Fab, Inc.