

TruFLOW visual flow meters

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

 Material
 Brass

 End type 1
 ISO 228-G 3/4"

 End type 2
 ISO 228-G 3/4"

Temp/pressure ratings $\,$ 73 °F (23 °C) at 160 psi (11 bar)

180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

Prop 65 label required? Yes

Product information and application use

Use the TruFLOW™ Visual Flow Meter on TruFLOW Jr. and TruFLOW Classic Manifolds to accurately measure the flow of hydronic radiant loops. The meter is available in a low range (A2640015), which measures 0.15 to 0.8 gpm and a high range (A2640027), which measures 0.25 to 2.0 gpm.



Part name	Part no.	A [inch]	B [inch]	C [inch]	Cv	Weight per UOM [lbs/UOM]
Replacement O-ring for TruFLOW Flow/Temperature Meter	A2620009	0.59	0.59	0.103	-	0
TruFLOW Visual Flow Meter, 0.15 to 0.8 gpm	A2640015	2.623	1.32	1.178	1.23	0.28
TruFLOW Visual Flow Meter, 0.25 to 2.0 gpm	A2640027	2.677	1.035	1.035	1.51	0.28

Installation Related applications

Assemble the TruFLOW Visual Flow Meter on the return manifold and observe that the water flows in the same direction as the arrow on the body of the meter. The TruFLOW Visual Flow Meter may be installed in a vertical or horizontal position. Do not install the TruFLOW Visual Flow Meter upside-down (arrow pointing downward) as it will affect the accuracy of the reading. Do not use any solvent-based cleaner to clean the measuring windows.

Radiant Heating and Cooling Systems
Permafrost Protection Systems

Turf Conditioning Systems

Codes	Standards	Listings
•	ASTM F877 R20:	-

Notes

Precision: +/-0.05gpm

Measuring Range: 0.15 gpm to 0.8 gpm

Connection: R20 QS-style

Precision: +/-0.05gpm

Measuring Range: 0.40 gpm to 2.0 gpm

Connection: R20 QS-style

Footnotes	Contact ir	Contact information			
	Uponor Inc.	Uponor Ltd.			
	5925 148th Street West	6510 Kennedy Road			
-	Apple Valley, MN 55124	Mississauga, ON L5T 2X4			
	T 800.321.4739	T 888.594.7726			
	F 952.891.2008	F 800.638.9517			