

RCB301AN, RCB399AN

RINNAI COMMERCIAL BOILER











CERTIFIED TO ANSI Z21.13 - CSA 4.9


Appliance Type	Condensing Wall-Mounted, Gas-Fired, Heat- Only (Solo) Boiler	
Installation Type	Internal (Indoor) Commercial Applications	
Model Numbers	RCB301AN, RCB399AN	
Gas Types	Natural and Propane	
	IMPORTANT: Units ship as Natural Gas only. Propane Conversion Kits available as accessory (purchased separately)	
Certifications	ANSI Z21.13, CSA 4.9, ASME	
Included with Purchase	 Boiler Wall Mounting Bracket with Screws Pressure Relief Valve: 75 PSI (5.2 bar) Outdoor Temperature Sensor Documentation: Installation and Operation Manual, User Manual, Warranty Card 	
Optional Accessories	Condensate Neutralizer, Air Inlet Filter, Cascade System Sensor, Boiler Rack, Gas Conversion Kit, BACnet Adapter, and BACnet Adapter with LonWorks.	


VENTING OPTIONS

Direct Vent



Non-Direct Vent (Room Air)





Bottom View




Table: Connection Sizes


Connection	Connection Size	Minimum Pipe Size
Gas	1 in. NPT	1in.
CH In (CH Return)	1-1/4 in. NPT	1-1/4 in.
CH Out (CH Supply)	1-1/4 in. NPT	1-1/4 in.
Condensate Drain	1 in. NPT	3/4 in.
Venting (Intake & Exhaust)	4 in. PVC/CPVC	4 in.

Model		RCB301AN	RCB399AN	
IgnitionSystem		Direct Electronic Ignition		
Dimensions - w, h, d		19.4 in. x 35.75 in. x 21.8 in. (493 mm x 908 mm x 554 mm)		
Weight (Shipping)		194 lb (88 kg)	207lb (94 kg)	
Weight (Appliance)		170 lb (77 kg)	183 lb (83 kg)	
Heat Exchanger Surface Area		24.6 sq ft	30.7 sq ft	
Gas Consumption (Btu/h)	Minimum	30,100	39,900	
	Maximum	301,000	399,000	
Temperature	СН	(Minimum - Maximum) 86°F - 180°F (30°C - 82°C)		
Setting	Indirect Tank (DHW)	104°F - 176°F (40°C - 80°C)		
Water Content Content		1.8 gal (6.8 lt)	2.2 gal (8.3 lt)	
Water Pressure	СН	Minimum: 14.5 PSI (1 bar) Maximum: 87 PSI (6 bar) Maximum Allowable Water Pressure (MAWP): 160 PSI (1103 kPa)		
	PRV	75 PSI (5.2 bar) (Pressure Relieve Valve included with system)		
Sound Level		55 dB(A)	56 dB(A)	
	Normal	133 W	210 W	
Electrical Data	Standby	10 W		
Liectrical Data	Max Current	6.3 Amps		
	Fuse	2 x 6.3 Amps		
Gas Supply Pressure ¹	Natural Gas	3.5 in 10.5 in. wc (0.87 - 2.61 kPa)		
	Propane	8.0 in 13.5 in. wc (1.99 - 3.36 kPa)		
Electric Connections		AC 120 Volts, 60 Hz		
Certifications		ANSI Z21.13, CSA 4.9, ASME		
Canada CRN		Y6325.2C		
Warranty		Heat Exchanger: 10 Years. All Other Parts & Components: 1 Year. Reasonable Labor: 1 Year. See the "Rinnai Commercial Boiler Warranty" for Complete Details		
Venting 45° elbow is equivalent to 3 ft (1 m). 90° elbow is equivalent to 6 ft (2 m).	Options:	Direct Vent Non-Direct Vent (Room Air)		
	Materials	PVC, CPVC, PP and Stainless Steel		
	Vent Size	4 in. PVC/CPVC		
	Exhaust	Vent Run (Min-Max): 10 ft (3 m) - 140 ft (43 m)		
	Intake	Vent Run (Min-Max): 0 ft (0 m) - 140 ft (43 m)		
	High Altitude	 0-2,000 feet (0-609 m) - 140 ft (43 m) For altitudes above 2,000 ft (609 m), vent length is reduced to 90 ft (27 m). 		


¹ Maximum gas supply pressure must not exceed the value specified by the manufacturer.

CLEARANCES

Location	Clearance	
Тор	4 in. (102 mm) 0 in. from vent components	
Bottom (Ground)	12 in. (305 mm)	
Front	6 in. (152 mm) Clearance for servicing is 24 in. (610 mm) in front of boiler	
Back	0 in. (0 mm)	
Sides (Left and Right)	2 in. (51 mm) Clearance for servicing is 12 in. (305 mm) on the sides.	
Vent	0 in. (0 mm)	



PRESSURE DROP AND WATER FLOW CURVE WITH HYDRAULIC SEPARATION



The Rinnai Commercial Boiler does not have an included boiler pump. An external boiler pump must be installed and sized to the flow rate and pressure drop through the boiler, system piping, and system components. Larger systems, or systems with large pressure drops, should incorporate a form of hydraulic separation, such as closely spaced tees or a low loss header.

Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269 1-800-621-9419 • rinnai.us • rinnai.ca

©2023 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.

800000176 11/2023