



SUBMITTAL DATA SHEET

One Way Cassette Heat Pump System

Location: _____
 Engineer: _____
 Submitted to: _____
 Submitted by: _____
 Reference: _____


Approval: _____
 Date: _____
 Construction: _____
 Unit #: _____
 Drawing #: _____

Set Model
 Indoor unit model: CCOXHA1C09

Certified

AHRI

UL



| REFRIGERANT PIPE DATA | | |
|-------------------------------|--------|-------------|
| Design pressure | (PSIG) | 550/340 |
| Refrigerant Type | | R410A |
| Liquid side/ Gas side(indoor) | (inch) | 1/4" / 3/8" |
| Connection method | | Flared |

| OPERATING RANGE | | |
|-----------------|-----------|-------|
| Indoor(cooling) | (Deg. °F) | 60~90 |
| Indoor(heating) | (Deg. °F) | 32~86 |

| DIMENSIONS | | |
|-------------------|--------|-------------------|
| Dimension (WxDxH) | (inch) | 50.31x13.19x8.98 |
| Packing(WxDxH) | (inch) | 57.60x22.48x22.64 |
| Net/Gross weight | (lbs.) | 43.87/81.35 |

| INDOOR UNIT DATA | | | |
|---------------------------------------|---------|--|-----------------------------|
| Indoor fan motor | | | |
| Model | | | ZKFN-30-8-43 |
| Qty | | | 1 |
| Input | (W) | | / |
| Output | (W) | | 30.0 |
| RLA | (A) | | 0.80 |
| Speed(Hi/Mi/Lo) | (r/min) | | 1024/944/784 |
| Air flow & Noise level | | | |
| Indoor air flow (Hi/Med/Lo) (No duct) | (CFM) | | 341.18/294.12/258.82/235.29 |
| Indoor noise level (Hi/Med/Lo) | [dB(A)] | | 37.5/35.5/31 |
| Dehumidification | (L/H) | | 1.02 |

Indoor unit dimensions

