



SUBMITTAL DATA SHEET

Wall Mounted Heat Pump System


| | |
|---------------------|---------------------|
| Location: _____ | Approval: _____ |
| Engineer: _____ | Date: _____ |
| Submitted to: _____ | Construction: _____ |
| Submitted by: _____ | Unit #: _____ |
| Reference: _____ | Drawing #: _____ |

Set Model
Indoor unit model: CCOXHAWM06HP

Certified

AHRI

UL



REFRIGERANT PIPE DATA

| | | |
|-------------------------------|--------|-----------|
| Design pressure | (PSIG) | 32.8 |
| Refrigerant Type | | 6.35/9.52 |
| Liquid side/ Gas side(indoor) | (inch) | 1/4"/3/8" |
| Connection method | | Flared |

OPERATING RANGE

| | | |
|-----------------|-----------|-------|
| Indoor(cooling) | (Deg. °F) | 60~90 |
| Indoor(heating) | (Deg. °F) | 32~86 |

DIMENSIONS

| | | |
|-------------------|--------|-------------------|
| Dimension (WxDxH) | (inch) | 33.40x9.18x11.76 |
| Packing(WxDxH) | (inch) | 36.22x12.20x14.57 |
| Net/Gross weight | (lbs.) | 22.71/28.88 |

INDOOR UNIT DATA

Indoor fan motor

| | | |
|-----------------|---------|---------------|
| Model | | ZKFP-20-8-6-7 |
| Qty | | 1 |
| Input | (W) | 50.00 |
| Output | (W) | 20.0 |
| RLA | (A) | 0.4 |
| Speed(Hi/Mi/Lo) | (r/min) | 1050/930/870 |

Air flow & Noise level

| | | |
|---------------------------------------|---------|-----------------------------|
| Indoor air flow (Hi/Med/Lo) (No duct) | (CFM) | 364.71/317.65/217.65/167.65 |
| Indoor noise level (Hi/Med/Lo) | [dB(A)] | 36/32/23 |

Dehumidification

| | | |
|--|-------|------|
| | (L/H) | 0.15 |
|--|-------|------|

Indoor unit dimensions

