## υροποι

## Horizontal sidewall sprinklers

| Project information            |                 |
|--------------------------------|-----------------|
| Job name:                      | Location:       |
| Engineer:                      | Date submitted: |
| Contractor:                    | Submitted by:   |
| Manufacturer's representative: | Approved by:    |
| Teshsiatiat                    |                 |

| Temp/pressure ratings   | 73 °F (23 °C) at 160 psi (11 bar)   |
|-------------------------|-------------------------------------|
|                         | 180 °F (82 °C) at 100 psi (6.9 bar) |
|                         | 200 °F (93 °C) at 80 psi (5.5 bar)  |
| Prop 65 label required? | Yes                                 |

## Product information and application use

Horizontal sidewall sprinklers thread onto Uponor's fire sprinkler adapter fittings. Sprinklers are NSFand UL-approved for combined plumbing and fire sprinkler systems. Sprinklers designated LF are also NSF Annex G compliant. Note: Protective plastic caps, escutcheons and covers sold separately.



| Part name  | Part no.  | Weight per UOM [lbs/UOM] |
|--|-----------|--------------------------|
| LF Flat Concealed Horizontal Sidewall Sprinkler, 165F, 4.0<br>K-factor   | LF74000HS | 0.15                     |
| LF Recessed Horizontal Sidewall Sprinkler, 155F, 4.2 K-<br>factor, White | LF74300HW | 0.15                     |
| LF Recessed Horizontal Sidewall Sprinkler, 175F, 4.2 K-<br>factor, White | LF74301HW | 0.15                     |

| Installation   | Related applications          |
|--|-------------------------------|
| Do not store sprinkler assemblies where the ambient temperature will exceed 100°F. Recessed sprinkler wrench required to assemble sprinkler and adapter. | AquaSAFE™ Fire Safety Systems |

| Codes                         | Standards | Listings               |                         |  |
|-------------------------------|-----------|------------------------|-------------------------|--|
| -                             | -         |                        |                         |  |
|                               |           |                        |                         |  |
| Footnotes Contact information |           | nformation             |                         |  |
|                               |           | Uponor Inc.            | Uponor Ltd.             |  |
|                               |           | 5925 148th Street West | 6510 Kennedy Road       |  |
| -                             |           | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 |  |
|                               |           | T 800.321.4739         | T 888.594.7726          |  |
|                               |           | F 952.891.2008         | F 800.638.9517          |  |