

TruFLOW Jr. supply manifolds with balancing valves

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

 Material
 Brass

 Manifold size
 1 inch

 Loop Cv
 1.9 Cv

 End type 1
 ISO 228-G 1-1/4"

 End type 2
 ISO 228-G 3/4"


Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar)

180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

Max. fluid flow rate 14 gpm Prop 65 label required? Yes

Product information and application use

Use the TruFLOW™ Jr. Manifold with Balancing Valves in conjunction with the TruFLOW Jr. Manifold with Isolation Valves or the TruFLOW Jr. Valveless Manifold to complete the manifold set. The TruFLOW Jr. Manifold with Balancing Valves allows manual flow balancing of the individual loops on the manifold.





Part name	Part no.	B [inch]	C [inch]	Weight per UOM [lbs/UOM]
TruFLOW Jr. Manifold Balancing Valves, 2-loop	A2663212	-	-	2.4
TruFLOW Jr. Manifold Balancing Valves, 3-loop	A2663213	-	-	3.2
TruFLOW Jr. Manifold Balancing Valves, 4-loop	A2663214	9.6	3.07	3.9

Installation Related applications

For more information, refer to the Uponor TruFLOW Jr. Manifold Instruction Sheet or the Uponor Complete Design Assistance Manual. Accessories: TruFLOW Jr. Manifold Bracket: A2640021; End Cap with Vent: A2803250; Basic End Cap: A2080032.

Radiant Heating and Cooling Systems
Permafrost Prevention Systems

Turf Conditioning Systems

Codes	Standards	Listings
IMC IRC NBC of Canada UMC	CSA B137.5 R32:	cNSFus-rfh

Notes

Manifold body threaded connections: R32 Manifold loop threaded connections: R20

Manifold body threaded connections:

R32

Manifold loop threaded connections: R20

Footnotes	Contact in	Contact information		
	Uponor Inc.	Uponor Ltd.		
	5925 148th Street West	6510 Kennedy Road		
-	Apple Valley, MN 55124	Mississauga, ON L5T 2X4		
	T 800.321.4739	T 888.594.7726		
	F 952.891.2008	F 800.638.9517		